

## **RESOLUTION NO. 2010-506**

Adopted by the Sacramento City Council

August 24, 2010

### **APPROVING CHANGE ORDER NO. 4 FOR THE CONSTRUCTION CONTRACT WITH COLLINS ELECTRICAL COMPANY, INC. IN AN AMOUNT NOT TO EXCEED \$27,335 FOR THE HISTORIC DEPOT BUILDING ELECTRICAL RE-FEED PROJECT (T15029005)**

#### **BACKGROUND**

- A. In December 2006, the City purchased the Historic Depot Building and the surrounding parcel. The existing electrical service to the Historic Depot Building is antiquated and in very poor condition.
- B. Change Order No. 4 includes work required to fix more code violations that have been discovered during demolition and construction, and install new feeders for a water heater and unknown panel, a ground jumper across the main water line, and a new decorative wrought iron fence to enclose the new Sacramento Municipal Utility District (SMUD) transformer and water main backflow preventer area, providing a secure and screened utility area. This change order is necessary to finish the project and keep it on schedule to be completed prior to the start of the Track Relocation Project.

#### **BASED ON THE FACTS SET FORTH IN THE BACKGROUND, THE CITY COUNCIL RESOLVES AS FOLLOWS:**

- Section 1. The City Manager or the City Manager's designee is authorized to execute Change Order No. 4 to Contract No. 2010-0023 with Collins Electrical Company, Inc. in an amount not to exceed \$27,335 for a revised total contract amount not to exceed \$477,676 for the Historic Depot Building Electrical Re-Feed Project.
- Section 2. All previous change orders issued for this project under the City Manager's signature authority are hereby ratified.


Adopted by the City of Sacramento City Council on August 24, 2010 by the following vote:

Ayes: Councilmembers Cohn, Fong, Hammond, McCarty, Pannell, Sheedy, Tretheway, Waters, and Mayor Johnson.

Noes: None.


Abstain: None.

Absent: None.



\_\_\_\_\_  
Mayor Kevin Johnson

Attest:



\_\_\_\_\_  
Shirley Concolino, City Clerk