

RESOLUTION NO. 2005-897

Adopted by the Sacramento City Council

December 13, 2005

AWARDING A CONSTRUCTION CONTRACT TO SYBLON REID FOR THE SACRAMENTO RIVER WATER TREATMENT PLANT (SRWTP) 9.5 MG RESERVOIR VALVE INSTALLATION PROJECT (PN: ZH51)

BACKGROUND

- A. The existing valves on the Sacramento River Water Treatment Plant reservoir's piping no longer work and the reservoir cannot be taken out of service for maintenance or repairs without taking the Sacramento River Water Treatment Plant (SRWTP) out of service.
- B. This is the first phase of work proposed for the SRWTP 9.5 MG Reservoir. Phase two will consist of performing seismic retrofits and replacing the reservoir's roof.
- C. City staff has prepared a set of plans and specifications to install two new 60-inch diameter butterfly valves on the reservoir's piping to improve reliability and safety. The project was advertised for bidding and bids were received on November 9, 2005.
- D. The two lowest bids received were non-responsive, so that the lowest responsive responsible bidder was Syblon Reid, with a bid of \$227,450.

BASED ON THE FACTS SET FORTH IN THE BACKGROUND AND REPORT TO COUNCIL, THE CITY COUNCIL RESOLVES AS FOLLOWS:

- Section 1. The City Council finds and determines that the recitals set forth above are true.
- Section 2. The bid proposals submitted by Clyde G. Steagall Inc. and TNT Industrial Contractors are rejected as non-responsive, and the City Manager and City Clerk are authorized to sign a construction contract with Syblon Reid for the SRWTP 9.5 MG Reservoir Valve Installation project (PN: ZH51) for an amount not to exceed \$227,450.


Adopted by the City of Sacramento City Council on December 13, 2005 by the following vote:

Ayes: Councilmembers Cohn, Fong, Hammond, McCarty, Pannell, Sheedy, Tretheway, Waters and Mayor Fargo.

Noes: None.

Abstain: None.

Absent: None.



Mayor Heather Fargo

Attest:



Shirley Concolino, City Clerk