

Item No. 6

Supplemental Material
For
City of Sacramento
Planning Commission
Agenda Packet

For the Meeting of: May 10, 2012



Additional Material
Revised Material

Contact Information: Ellen Marshall, Associate Planner, 808-5851

Project Name: Primo's Supper Club (P12-008)

Subject:

Additional advisory notes for the project from Solid Waste:

- ADV12. Project must meet the requirements outlined in Sacramento City Code Chapter 17.72.
- ADV13. Solid waste trucks must be able to safely move about the property, with minimum backing, and be able to empty the bins and cans safely. Current placement of trash enclosure appears to meet this.
- ADV14. Properties must accommodate trucks, as well as cans or bins, that are roughly the dimensions outlined in the "Truck, Bin, and Can Dimensions" section, on the next page.
- ADV15. Solid waste driver must not have to move front-loader bins more than 15 ft. for collection. Current placement of trash enclosure appears to meet this.
- ADV16. Due to the four apartment units upstairs, this building must have the solid waste collected by the City of Sacramento, per City Code.
- ADV17. The property must have enough weekly capacity of both trash and recycling to meet the requirements are outlined in 17.72.030, which for this project is 1 cubic yard for trash, and another 1 cubic yard for recycling.
- ADV18. Statement of Recycling required, including a description of trash and recycling operations after the building is built and occupied. The applicant has already met this requirement.